

State of North Carolina
Department of Environment,
Health and Natural Resources
Winston-Salem Regional Office

James B. Hunt, Jr., Governor
Jonathan B. Howes, Secretary
Leesha Fuller, Regional Manager



DIVISION OF ENVIRONMENTAL
MANAGEMENT
GROUNDWATER SECTION

March 21, 1994

Jack D. Greer
Ladd Furniture, Inc.
American Drew Operations
PO Box 489
North Wilkesboro, NC 28659-0489

SUBJECT: Underground Storage Tank (UST) Closure Assessment at American Drew -
Plant #14, Highway 268 East, North Wilkesboro, Wilkes County

Dear Mr. Greer:

The Groundwater Section of the Winston-Salem Regional Office is now reviewing the UST closure assessment for the subject location. In order to determine whether or not the closure was performed in accordance with State and Federal regulations, the Groundwater Section must be provided with the following information:

Indicate the depth of tank burial.

Indicate location of any pump island or lines if applicable. If a pump island was present and was not sampled as part of the tank excavation, please sample that area and test using appropriate methods. One sample for every 20 feet of line and one sample for every ten feet of island.

Your co-operation is appreciated. Please refer to the file name, **American Drew Plant #14**, on the cover letter of your reply. This will help us speed up the review.

If you have any questions please contact me at the letterhead address and/or telephone number.

Sincerely,

Sabra A. Murphy
Hydrogeological Technician II

8025 North Point Boulevard, Suite 100, Winston-Salem, North Carolina 27106-3203

Telephone 910-896-7007 FAX 910-896-7005

An Equal Opportunity Affirmative Action Employer

50% recycled/ 10% post-consumer paper